



ADJUSTING GRADE RING SIZE		
2"	X	3"
2 1/2"	X	3 1/2"
3"	X	4"

NOTES:

1. PRECAST CONCRETE $f_c' \times 5000$ PSI @ 28 DAYS.
2. REINFORCEMENT CONFORMS TO ASTM C-478.
3. INSTALL MORTAR NOT LESS THAN 1/4 INCH THICK BETWEEN RING.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

[Signature] 6/29/95
DIRECTOR OF DEVELOPMENT SERVICES DATE

[Signature] 6/29/95
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

24" PRECAST CONC.
MANHOLE SLOPED
ADJUSTING GRADE
RING

REVISIONS:

S
3.07